

In Part 7.3 Technical Specifications, it states that Section 13850 -  
Fire

>> Detection and Alarm System, Direct Current Loop shall be used.

>>

>> I cannot find what are the requirements for any type of fire detection

>> required in these facilities.

>>

>> Please provide a) Fire deception and requirements per building,

>> b) Is a connection required to the Host Installation?

>> Where? What type of system?

>> **THE DESIGNER SHALL SPECIFY THE FIRE ALARM SYSTEM REQUIRED BASED ON THE "DESIGN MANUAL FOR REMOTED TARGET SYSTEM (RETS) RANGES", THE "FORT LEONARD WOOD STANDARD DESIGN REQUIREMENTS AND OTHER STATED REQUIREMENTS. AT A MINIMUM THE AIR HANDLING UNIT FOR THE CLASSROOM SHOULD HAVE SMOKE DETECTOR SHUTDOWN.**

>> Glenn S. Berger, P.E.

>> Fire Protection Engineer

>> Black & Veatch

>> 6601 College Blvd.

>> Overland Park, KS 66211

>>

>> Direct: 913-458-9440

>> Fax: 913-458-9392

>> Email: BergerGS@bv.com

>>

>